

Cost-effective solutions for river water quality improvement in Eindhoven supported by sewer-WWTP-river integrated modeling

Lorenzo Benedetti¹, J. Langeveld², J.J.M. de Klein³, I. Nopens⁴, A. van Nieuwenhuijzen⁵, T. Flameling⁶, O. van Zanten⁶ and S. Weijers⁶

¹ WATERWAYS srl, Via del Ferrone 88, 50023 Impruneta (FI), Italy

² Delft University of Technology, Stevinweg 1, 2624 CN Delft, Netherlands

³ Aquatic Ecology and Waterquality Management Group, Wageningen University and Research centre, P.O. Box 47, 6700 AA Wageningen, Netherlands

⁴ BIOMATH, Department of Mathematical Modelling, Statistics and Bioinformatics, Ghent University, Coupure Links 653, 9000 Gent, Belgium

⁵ Witteveen+Bos, PO Box 233, NL-7400 AE Deventer, Netherlands

⁶ Waterschap De Dommel, 5280 Boxtel, Netherlands

- The Kallisto project
- System definition
- Project approach
- Selection of measures
- Scenario analysis
- Conclusions

Waterschap
De Dommel



gemeente Eindhoven

WATER / SCHAP
Vallei & Em



stowa



WAGENINGEN UNIVERSITEIT
WAGENINGEN UR




UNIVERSITEIT
GENT


WATERWAYS




Agentschap NL
Ministerie van Infrastructuur en Milieu



Together



Smart



Clean

Clean: Improving the receiving surface water quality to **comply** with the national legislation and the **EU Water Framework Directive**

Smart: Controlling storm water and wastewater flows by **cost-effective** control, buffering and treatment measures in the **Integrated** Urban Water System

Together: Involving different **stakeholders** in the water chain across the boundaries of responsibilities including municipalities, the waterboard, knowledge institutes and STOWA (dissemination)

The Eindhoven system



Complex combined
wastewater system

Large area with severe
impact on vulnerable
surface water

10 municipalities


750,000 PE WWTP

>200 CSOs


The Eindhoven WWTP




The Dommel River: ecological quality




Dry weather




Rain weather




Storm weather




Storm weather + overflow




Water Quality Policy / WFD




Water Quality Policy / WFD




Modeling (after monitoring)






sewer




WWTP




river

- One single model:
 - Mass and information flows (impact on receiving water, RTC)
- Speed:
 - Many scenarios
 - Long-term simulation (10y in 2h)
 - Monte Carlo for UA/SA


Integrated model results: DO at river section DS of WWTP




Modeling



GSA: operational parameters ranking



Modeling



Measure	Field of application/objective
RTC in the sewer system	Minimisation of DO dips and/or NH ₄ peaks in river with available system capacity
DAF, fine screens, lamella settler, fuzzy filter	Pre-treatment of wastewater during DWF Treatment of WWF
CSO storage	Reduction of CSO emissions
Dry buffers at WWTP inlet	Peak load shaving to reduce NH ₄ concentration peaks in effluent
River aeration	Reduce DO dips in river
Effluent aeration	Reduce DO dips in river due to WWTP effluent
WWTP: additional aeration capacity, increase of MLSS and of aeration volume	Enhance nitrification process to reduce NH ₄ peak concentrations in river
Equalisation pond/wetland	Equalisation of WWTP effluent to reduce NH ₄ peak concentrations to the river
Increase interceptor/pumping capacities	Reduce DO dips in river
Increase hydraulic capacity of biological treatment at WWTP	reduce NH ₄ peak concentrations and DO dips in river
Sand filter for treatment of WWTP effluent	Reduce N _{total} and P _{total} in effluent

Scenario analysis

- **10-year dynamic** simulations
- Approx. **40** different scenarios tested
- Evaluation
 - Ecological framework based on **concentration-duration-frequency** curves for sensitive species
 - Focus on **DO** and **NH₄**
 - Costs (**CAPEX** and **OPEX**)

Scenario analysis: costs

Costs of measures to reduce **DO** depletion
and achieve basic DO levels

Measure	Investment	CAPEX	OPEX
Additional storage	€ 79,800,000	€ 3,830,000	€ 79,500
River aeration	€ 1,040,000	€ 96,700	€ 117,000

Scenario analysis: costs

Reference scenario:

- conventional methods of solving water quality issues (**uncoupling** of paved area, building sewer **storage** facilities at CSOs)
- yearly cost (CAPEX+OPEX) approximately **€ 15 million**

Scenario analysis: costs

Scenario	A	B	C
Measure in all scenarios	River aeration + effluent aeration Sand filter for effluent filtration RTC aiming at reducing NH ₄ concentration peaks Additional aeration capacity at WWTP		
Measures	dry storage	wetland	DAF pre-treatment
Investment	€ 160,140.000	€ 90,410.000	€ 36,780.000
CAPEX	€ 11,295,000/year	€ 8,328,000/year	€ 3,052,000/year
OPEX	€ 3,670,00/year	€ 3,194,000/year	€ 4,641,000/year
Total annual costs (CAPEX + OPEX)	€ 14,965,000/year	€ 11,522,000/year	€ 7,693,000/year

Scenario analysis: water quality

current situation

WWTP



NH ₄		Duration of the event				S066				S000				S017				S010				S008				S031																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																												
		1 - 5 h	6 - 24 h	> 24 h																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		

scenario C
(RTC + riv.aer. + DAF)

WWTP



NH ₄		Duration of the event				S066				S000				S017				S010				S008				S031														
		1 - 5 h	6 - 24 h	> 24 h																																				
Tolerated	12	1.5	0.7	0.3	1	2	1	0.6	6.1	2.8	1	1	1	0.3	1.6	0.2	1	4	2	0.4	14.8	6.8	1	2	2	1.9	7.2	9.4	1	2	2	3.2	8.0	8.1	1	1	2	0.7	6.0	6.8
frequency	4	2	1.2	0.5	1	1	1	0.0	1.6	0.9	1	1	1	0.0	0.1	0.1	1	1	3	0.0	1.4	4.6	1	1	2	0.9	1.8	3.4	1	2	1	0.4	2.1	0.7	1	1	1	0.0	1.3	0.7
per year	1	2.5	1.5	0.7	1	2	2	0.0	0.7	0.6	1	1	1	0.0	0.0	0.1	1	1	4	0.0	0.5	1.9	1	2	4	0.0	0.9	1.4	1	1	1	0.0	0.3	0.2	1	1	1	0.0	0.2	0.1
	0.2	4.5	3	1.5	1	1	1	0.0	0.0	0.1	1	1	1	0.0	0.0	0.1	1	1	4	0.0	0.0	0.3	1	1	1	0.0	0.0	0.1	1	1	1	0.0	0.0	0.1	1	1	1	0.0	0.0	0.1
DO critical		Duration of the event																																						
		1 - 5 h	6 - 24 h	> 24 h																																				
Tolerated	12	5.5	6	7	1	1	1	0.3	4.2	3.9	1	1	2	0.0	0.0	9.8	1	2	2	0.0	8.0	8.4	1	1	2	0.0	0.0	10.5	1	1	1	0.0	0.0	0.9	1	1	2	0.0	0.1	8.0
frequency	4	4	5.5	6	1	1	1	0.1	2.0	0.7	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	1.4	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.1
per year	1	3	4.5	5.5	1	1	1	0.0	0.3	0.2	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0
	0.2	1.5	2	3	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0
DO basic		Duration of the event																																						
		1 - 5 h	6 - 24 h	> 24 h																																				
Tolerated	12	3	3.5	4	1	1	1	0.0	0.0	0.1	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0
frequency	4	2.5	3	3.5	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0
per year	1	2	2.5	3	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0
	0.2	1	1.5	2	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0	1	1	1	0.0	0.0	0.0

Conclusions

Integrated model used to describe the **dynamics** of the whole urban wastewater system and evaluate **cost-effective** upgrade scenarios to comply with specific **water quality regulation**

Several upgrade options are available to achieve the desired water quality in terms of **DO** and **NH₄**

There are **substantial cost differences** between scenarios, with clear advantages in using **in-stream aeration** for DO depletion and WWTP **DAF** pre-treatment for NH₄ peaks


The integrated model proved to be a very powerful tool to quickly investigate **interactions**, **synergies** and **conflicts** in the system

Perspectives

Next 2 years implementation:

- Sewer RTC
- WWTP higher inflow + RTC upgrade
- DAF demo 1500 m³/h
- River aeration one station upstream WWTP

THANK YOU !!!



more details on RTC Wed 10:30 session **87**

lorenzobenedetti@waterways.it